

**Part III Form 2
Section 11. ANNUAL REPORT.**

Drinking-Water System Number:	260051662
Drinking-Water System Name:	North Wallaceburg Distribution System
Drinking-Water System Owner:	Municipality of Chatham-Kent
Drinking-Water System Category:	Small Municipal Residential
Period being reported:	January 1 – December 31, 2007

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> Chatham-Kent PUC Office 325 Grand Ave., East P.O. Box 1191 Chatham, Ontario N7M 5L8 </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No [] </p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No [] </p>
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
 Yes [] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method

Describe your Drinking-Water System

The North Wallaceburg Distribution System is an extension of the St. Clair Township Water Distribution System. The North Wallaceburg system connects at the Lambton / Kent County border on St. Clair Parkway Road and continues to Stewart Line and branches off to supply customers on Payne and Bishop Roads. The water that is supplied to these systems is produced by the Lambton Area Water Supply System plant in Sarnia.

List all water treatment chemicals used over this reporting period

None

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Drinking-Water Systems Regulation O. Reg. 170/03

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A					
N/A					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples or Background Colony Counts	Range of HPC Results or Background Colony Counts (min #)-(max #)
Raw	N/A				
Treated	N/A				
Distribution	104	0 - 0	0 - 0	104	9 - 30

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	N/A	
Chlorine	395	0.35 – 1.59 mg/L
Fluoride (If the DWS provides fluoridation)	N/A	

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				
N/A				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date Jan. 11/07	Sample Date April 12/07	Sample Date July 10/07	Sample Date Oct. 05/07
Antimony	N/A	N/A	N/A	N/A
Arsenic	N/A	N/A	N/A	N/A
Barium	N/A	N/A	N/A	N/A
Boron	N/A	N/A	N/A	N/A
Cadmium	N/A	N/A	N/A	N/A
Chromium	N/A	N/A	N/A	N/A
Lead – ug/L	<0.5	N/A	N/A	N/A
Mercury	N/A	N/A	N/A	N/A
Selenium	N/A	N/A	N/A	N/A
Sodium – ug/L	7000	N/A	N/A	N/A
Uranium	N/A	N/A	N/A	N/A
Fluoride – mg/L	0.5	N/A	N/A	N/A
Nitrite	N/A	N/A	N/A	N/A
Nitrate	N/A	N/A	N/A	N/A

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date Jan. 11/07	Sample Date April 12/07	Sample Date July 10/07	Sample Date Oct. 05/07
Alachlor	N/A	N/A	N/A	N/A
Aldicarb	N/A	N/A	N/A	N/A
Aldrin + Dieldrin	N/A	N/A	N/A	N/A
Atrazine + N-dealkylated metabolites	N/A	N/A	N/A	N/A
Azinphos-methyl	N/A	N/A	N/A	N/A
Bendiocarb	N/A	N/A	N/A	N/A
Benzene	N/A	N/A	N/A	N/A
Benzo(a)pyrene	N/A	N/A	N/A	N/A
Bromoxynil	N/A	N/A	N/A	N/A
Carbaryl	N/A	N/A	N/A	N/A
Carbofuran	N/A	N/A	N/A	N/A
Carbon Tetrachloride	N/A	N/A	N/A	N/A
Chlordane (Total)	N/A	N/A	N/A	N/A
Chlorpyrifos	N/A	N/A	N/A	N/A
Cyanazine	N/A	N/A	N/A	N/A
Diazinon	N/A	N/A	N/A	N/A
Dicamba	N/A	N/A	N/A	N/A
1,2-Dichlorobenzene	N/A	N/A	N/A	N/A
1,4-Dichlorobenzene	N/A	N/A	N/A	N/A
Dichlorodiphenyltrichloroethane (DDT) + metabolites	N/A	N/A	N/A	N/A
1,2-Dichloroethane	N/A	N/A	N/A	N/A

1,1-Dichloroethylene (vinylidene chloride)	N/A	N/A	N/A	N/A
Dichloromethane	N/A	N/A	N/A	N/A
2-4 Dichlorophenol	N/A	N/A	N/A	N/A
2,4-Dichlorophenoxy acetic acid (2,4-D)	N/A	N/A	N/A	N/A
Diclofop-methyl	N/A	N/A	N/A	N/A
Dimethoate	N/A	N/A	N/A	N/A
Dinoseb	N/A	N/A	N/A	N/A
Diquat	N/A	N/A	N/A	N/A
Diuron	N/A	N/A	N/A	N/A
Glyphosate	N/A	N/A	N/A	N/A
Heptachlor + Heptachlor Epoxide	N/A	N/A	N/A	N/A
Lindane (Total)	N/A	N/A	N/A	N/A
Malathion	N/A	N/A	N/A	N/A
Methoxychlor	N/A	N/A	N/A	N/A
Metolachlor	N/A	N/A	N/A	N/A
Metribuzin	N/A	N/A	N/A	N/A
Monochlorobenzene	N/A	N/A	N/A	N/A
Paraquat	N/A	N/A	N/A	N/A
Parathion	N/A	N/A	N/A	N/A
Pentachlorophenol	N/A	N/A	N/A	N/A
Phorate	N/A	N/A	N/A	N/A
Picloram	N/A	N/A	N/A	N/A
Polychlorinated Biphenyls(PCB)	N/A	N/A	N/A	N/A
Prometryne	N/A	N/A	N/A	N/A
Simazine	N/A	N/A	N/A	N/A
THM Jan., Apr., July, Oct.	41.2	37.2	49.9	68.9
THM Annual Average				49.3
Temephos	N/A	N/A	N/A	N/A
Terbufos	N/A	N/A	N/A	N/A
Tetrachloroethylene	N/A	N/A	N/A	N/A
2,3,4,6-Tetrachlorophenol	N/A	N/A	N/A	N/A
Triallate	N/A	N/A	N/A	N/A
Trichloroethylene	N/A	N/A	N/A	N/A
2,4,6-Trichlorophenol	N/A	N/A	N/A	N/A
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	N/A	N/A	N/A	N/A
Trifluralin	N/A	N/A	N/A	N/A
Vinyl Chloride	N/A	N/A	N/A	N/A

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
THM 100 ug/L	68.9	ug/L	Oct. 05/07
N/A			

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)