



OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	220003369
Drinking-Water System Name:	Ridgetown Drinking Water System
Drinking-Water System Owner:	Municipality of Chatham-Kent
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January - December 2017

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Chatham-Kent PUC Office 325 Grand Ave E Box 1191 Chatham, ON N7M 5L8</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
None	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [] No []



Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method _____

Describe your Drinking-Water System

Ground water for the Ridgetown Drinking Water System is obtained through seven deep wells. The drinking water system is comprised of two treatment facilities, one located on Erie Street South and the other located on Scane Road.

The four wells, Colby Well #1, Well #2 – Hitch, and Well #3A – Harris supply raw water from submersible well pumps through a common pipe to the treatment system at the Erie Street site. Water from these wells is disinfected with sodium hypochlorite and then passed through a cascade aerator for methane gas reduction before being discharged into reservoirs on site. Treated water from the North and South reservoirs is subsequently discharged to the distribution system by high lift pumps.

The remaining five wells, Well #S1 – Scane, Well #4 – Scane, Well #5 - Scane, and Well #7 – Scane, supply raw water from submersible well pumps through a common pipe to the treatment system at the Scane Road site. Water from these wells is disinfected with sodium hypochlorite and then passed through a cascade aerator for methane gas reduction before being discharged into the reservoir on site. Treated water from the reservoir is subsequently discharged to the distribution system by high lift pumps.

The distribution system for the Ridgetown Drinking Water System also includes an elevated tank for the storage and supply of water to the system.

Fluoride is naturally occurring in the source water in concentrations greater than the 1.5 mg/L Ontario Drinking Water Quality Standard. Sodium is also naturally occurring in the source water in concentrations greater than the 20 mg/L aesthetic objective.

List all water treatment chemicals used over this reporting period

1. Sodium Hypochlorite



Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Scane Highlift Pump #2 Rebuild.....	\$2,022
Elevated Tank & Scane Reservoir Inspection.....	\$5,000

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
October 31	Cl2 Residual > 4.0 mg/L into the Dist. System	4.18	mg/L	Resample, Test	October 31 & November 1

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	319	0 – 0	0 – 33	NA	NA
Treated	104	0 – 0	0 – 0	104	<10 – 240
Distribution	156	0 – 0	0 – 0	52	<10 – 50

- * NDOGN – No Data Overgrown With Non Target Organisms
- * NDOGT – No Data Overgrown With Target

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	255	0.110 – 0.960 NTU
Chlorine	8760	0.32 – 4.18 mg/L
Fluoride (If the DWS provides fluoridation)	Fluoride Naturally Occurring	

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled 2017	Result Erie	Result Scane	Unit of Measure
June 26, 2003 letter from C-K Health Unit	Point of Entry - Fluoride	Jan 16, 2017	1.8	1.9	mg/L

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value Erie	Result Value Scane	Unit of Measure	Exceedance
Antimony	Jan 11, 2016	<0.50	<0.50	ug/L	No
Arsenic	Jan 11, 2016	<1.0	<1.0	ug/L	No
Barium	Jan 11, 2016	96	180	ug/L	No
Boron	Jan 11, 2016	1000	980	ug/L	No
Cadmium	Jan 11, 2016	<0.10	<0.10	ug/L	No
Chromium	Jan 11, 2016	<5.0	<5.0	ug/L	No
*Lead	See Schedule 15.1 Summary				
Mercury	Jan 11, 2016	<0.10	<0.10	ug/L	No
Selenium	Jan 11, 2016	<2.0	<2.0	ug/L	No
Sodium	Jan 11, 2016	69	69	mg/L	Yes - Reported Jan 16, 2015 AWQI # 122310
Uranium	Jan 11, 2016	<0.10	<0.10	ug/L	No
Fluoride	Jan 16, 2017	1.8	1.9	mg/L	Yes - Reported Aug 20, 2013 AWQI # 113497
Nitrite	October 16, 2017	<0.010	<0.010	mg/L	No
Nitrate	October 16, 2017	<0.10	<0.10	mg/L	No

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results ug/L (min#) – (max #)	Number of Exceedances / Adverses
Residential	NA	NA	NA
Non-Residential	NA	NA	NA
Distribution	6	<0.50 – <0.50	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value Erie	Result Value Scane	Unit of Measure	Exceedance
Alachlor	Jan 11, 2016	<0.5	<0.5	ug/L	No
Atrazine + N-dealkylated metabolites	Jan 11, 2016	<1.0	<1.0	ug/L	No
Azinphos-methyl	Jan 11, 2016	<2	<2	ug/L	No
Benzene	Jan 11, 2016	<0.10	<0.10	ug/L	No
Benzo(a)pyrene	Jan 11, 2016	<0.009	<0.009	ug/L	No
Bromoxynil	Jan 11, 2016	<0.5	<0.5	ug/L	No
Carbaryl	Jan 11, 2016	<5	<5	ug/L	No
Carbofuran	Jan 11, 2016	<5	<5	ug/L	No
Carbon Tetrachloride	Jan 11, 2016	<0.10	<0.10	ug/L	No
Chlorpyrifos	Jan 11, 2016	<1	<1	ug/L	No
Diazinon	Jan 11, 2016	<1	<1	ug/L	No
Dicamba	Jan 11, 2016	<1	<1	ug/L	No
1,2-Dichlorobenzene	Jan 11, 2016	<0.20	<0.20	ug/L	No
1,4-Dichlorobenzene	Jan 11, 2016	<0.20	<0.20	ug/L	No
1,2-Dichloroethane	Jan 11, 2016	<0.20	<0.20	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Jan 11, 2016	<0.10	<0.10	ug/L	No
Dichloromethane	Jan 11, 2016	<0.50	<0.50	ug/L	No
2-4 Dichlorophenol	Jan 11, 2016	<0.25	<0.25	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Jan 11, 2016	<1	<1	ug/L	No
Diclofop-methyl	Jan 11, 2016	<0.9	<0.9	ug/L	No
Dimethoate	Jan 11, 2016	<2.5	<2.5	ug/L	No
Diquat	Jan 11, 2016	<7	<7	ug/L	No
Diuron	Jan 11, 2016	<10	<10	ug/L	No
Glyphosate	Jan 11, 2016	<10	<10	ug/L	No

Haloacetic Acids (Total) (NOTE: show latest annual average) 2017 - Distribution 13404 Reeders Line - Jan 16, 2017 13404 Reeders Line - Apr 3, 2017 SS #4 Arena 180 Main St.- Jul 10, 2017 SS #5 Colby Road - Oct 16, 2017	Jan 16, 2017 Apr 3, 2017 Jul 10, 2017 Oct 16, 2017 2017 Avg	<5.0 <5.0 <5.0 5.6 5.2	N/A	ug/L	No
Metolachlor	Jan 11, 2016	<0.5	<0.5	ug/L	No
2 Methal-4-chlorophenoxyacetic acid (MCPA)	Jan.11, 2016	<0.00012	<0.00012	mg/L	No
Metribuzin	Jan 11, 2016	<5	<5	ug/L	No
Monochlorobenzene	Jan 11, 2016	<0.10	<0.10	ug/L	No
Paraquat	Jan 11, 2016	<1	<1	ug/L	No
Pentachlorophenol	Jan 11, 2016	<0.5	<0.5	ug/L	No
Phorate	Jan 11, 2016	<0.5	<0.5	ug/L	No
Picloram	Jan 11, 2016	<5	<5	ug/L	No
Polychlorinated Biphenyls(PCB)	Jan 11, 2016	<0.05	<0.05	ug/L	No
Prometryne	Jan 11, 2016	<0.25	<0.25	ug/L	No
Simazine	Jan 11, 2016	<1	<1	ug/L	No
THM (NOTE: show latest annual average) 2017 - Distribution SS – 13404 Reeders Line 2016 POE ERIE: JAN 11 – 27.1 ug/L 2016 POE SCANE: JAN 11 – 20.5 ug/L	Jan 16, 2017 Apr 3, 2017 Jul 10, 2017 Oct 16, 2017 2017 Avg	34.6 35.6 36.4 33.5 35.0		ug/L	No
Terbufos	Jan 11, 2016	<0.5	<0.5	ug/L	No
Tetrachloroethylene	Jan 11, 2016	<0.10	<0.10	ug/L	No
2,3,4,6-Tetrachlorophenol	Jan 11, 2016	<0.5	<0.5	ug/L	No
Triallate	Jan 11, 2016	<1	<1	ug/L	No
Trichloroethylene	Jan 11, 2016	<0.10	<0.10	ug/L	No
2,4,6-Trichlorophenol	Jan 11, 2016	<0.5	<0.5	ug/L	No
Trifluralin	Jan 11, 2016	<1	<1	ug/L	No
Vinyl Chloride	Jan 11, 2016	<0.20	<0.20	ug/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value Erie	Result Value Scane	Unit of Measure	Date of Sample
Fluoride – POE	1.8	1.9	mg/L	Jan 16, 2017



Summary of additional voluntary sampling and testing during this reporting period.

Parameter	Result Value							Unit of Measure	Date of Sample
	Colby Well # 1	Hitch Well # 2	Harris Well # 3A	Scane Well # 4	Scane Well #5	Scane Well # 7	Scane Well #1		
Nitrite - Raw	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010	mg/L	Jan 16, 2017
Nitrate - Raw	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10		Jan 16, 2017
Nitrite - Raw	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010		Apr 3, 2017
Nitrate - Raw	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10		Apr 3, 2017
Nitrite - Raw	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010		Jul 10, 2017
Nitrate - Raw	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10		Jul 10, 2017
Nitrite - Raw	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010	<0.010		Oct. 16, 2017
Nitrate - Raw	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10	<0.10		Oct. 16, 2017