



ANNUAL REPORT

| | |
|--|--|
| Drinking-Water System Number: | 260024999 |
| Drinking-Water System Name: | South Chatham-Kent Drinking Water System |
| Drinking-Water System Owner: | Municipality of Chatham-Kent |
| Drinking-Water System Category: | Large Municipal Residential |
| Period being reported: | January 1 – December 31, 2020 |

Does your Drinking-Water System serve more than 10,000 people? Yes [X] No []

Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

| |
|--|
| Chatham-Kent PUC Office 325 Grand Ave E Box 1191 Chatham, ON N7M 5L8 |
|--|

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

| Drinking Water System Name | Drinking Water System Number |
|----------------------------|------------------------------|
| None | |

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No []



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web**
- Public access/notice via Government Office**
- Public access/notice via a newspaper**
- Public access/notice via Public Request**
- Public access/notice via a Public Library**
- Public access/notice via other method** _____

Describe your Drinking-Water System

Surface water for the South Chatham-Kent Drinking Water System is obtained from Lake Erie via an intake pipe and a raw water pumping station. The Kent County Raw Water Pumping Station supplies both the South Chatham-Kent Water Treatment Plant and the Chatham Water Treatment Plant with raw water. Raw water from the pumping station is pumped to the South Chatham-Kent Water Treatment Plant and is passed through microstrainers for fine particulate removal. Filtration is then provided by a dual train membrane filtration system equipped with hollow fiber membrane modules for 0.2 micron removal. Filtered water from the membrane units is then passed through granular activated carbon filters for taste and odour control. Filtered water is then disinfected with chlorine gas. Hydrofluosilicic acid is also added as an aid in the prevention of tooth decay. Filtered water is then discharged to the contact chambers and subsequently to the high lift pump well. Treated water from the high lift pump well is discharged by the high lift pumps to the distribution system. The distribution system for the South Chatham-Kent Drinking Water System also includes a reservoir/booster station and an elevated tank, both located in Blenheim, for the storage and supply of water to the system.

List all water treatment chemicals used over this reporting period

1. Chlorine Gas
2. Hydrofluosilicic Acid

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment



Please provide a brief description and a breakdown of monetary expenses incurred

| | |
|------------------------------|------------|
| Membrane Modules Replacement | \$ 120,000 |
| Reservoir Pump Replacement | 35,000 |
| New Turbidity Meter | 8,500 |
| Low Lift #2 Pump Rebuild | 6,000 |
| Chlorine Probe Replacement | 6,000 |

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|---------------|-----------|--------|-----------------|-------------------|------------------------|
| None | | | | | |

Microbiological testing done under the Schedule 10 of Regulation 170/03, during this reporting period.

| | Number of Samples | Range of E.Coli Or Fecal Results (min #)-(max #) | Range of Total Coliform Results (min #)-(max #) | Number of HPC Samples | Range of HPC Results (min #)-(max #) |
|---------------------|-------------------|--|---|-----------------------|--------------------------------------|
| Raw | 52 | 0 – 14 | 4 – 1300 | 0 | |
| Treated | 52 | 0 – 0 | 0 – 0 | 52 | <10 – 20 |
| Distribution | 507 | 0 – 0 | 0 – 0 | 498 | <10 – 90 |

Operational testing done under Schedule 7 of Regulation 170/03 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (min #)-(max #) |
|------------------------------------|------------------------|----------------------------------|
| Turbidity Filters | 8760 | 0.0001 – 0.991 NTU |
| Chlorine After Clearwell #2 | 8760 | 0.20 – 3.75 mg/L |
| Fluoride (Provided) | 8760 | 0.014 – 1.071 mg/L |

***NOTE:** For continuous monitors use 8760 as the number of samples.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

| Date of legal instrument issued | Parameter | Jan Result | Feb Result | Mar Result | Apr Result | May Result | Jun Result | Jul Result | Aug Result | Sept Result | Oct Result | Nov Result | Dec Result |
|---|---|----------------------|------------|------------|------------|------------|------------|------------|------------|-------------|------------|------------|------------|
| Municipal Drinking Water License # 027-102 Pages 12 & 15 Tables 3 & 7 Annual Average Concentration Limit: 25 mg/L | Residue Management: Total Suspended Solids (mg/L) | 18 | 14 | 18 | 9 | 9 | 6 | 26 | 13 | 14 | 21 | 16 | 22 |
| | | Annual Average: 15.5 | | | | | | | | | | | |

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value | MAC Limit | Unit of Measure | Exceedance |
|--------------------------|---|--------------|-----------|-----------------|------------|
| Antimony | January 13 | <0.50 | 6 | ug/L | No |
| Arsenic | January 13 | <1.0 | 10 | ug/L | No |
| Barium | January 13 | 15 | 1000 | ug/L | No |
| Boron | January 13 | 18 | 5000 | ug/L | No |
| Cadmium | January 13 | <0.10 | 5 | ug/L | No |
| Chromium | January 13 | <5.0 | 50 | ug/L | No |
| *Lead | See Schedule 15.1 Summary | | | | |
| Mercury | January 13 | <0.0001 | 0.001 | mg/L | No |
| Selenium | January 13 | <2.0 | 50 | ug/L | No |
| Sodium | January 13 | 8.6 | 20 | mg/L | No |
| Uranium | January 13 | 0.48 | 20 | ug/L | No |
| Fluoride | Continuous Monitoring Required: See Operational Section | | | | |
| Nitrite | October 19 | <0.010 | 1 | mg/L | No |
| Nitrate | October 19 | 0.13 | 10 | mg/L | No |
| Nitrite + Nitrate | October 19 | 0.13 | - | mg/L | No |

Summary of lead testing under Schedule 15.1 during this reporting period

| Location Type | Number of Samples | Range of Lead Results ug/L (min#) – (max #) | MAC Limit ug/L | Number of Exceedances / Adverses |
|-----------------|-------------------|---|----------------|----------------------------------|
| Residential | 0 | | | |
| Non-Residential | 0 | | | |
| Distribution | 8 | <0.50 – 0.64 | 10 | 0 |

Summary of Organic parameters sampled during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value | MAC Limits | Unit of Measure | Exceedance |
|--|---|------------------------------|------------|-----------------|------------|
| Alachlor | January 13 | <0.50 | 5 | ug/L | No |
| Atrazine + N-dealkylated metabolites | January 13 | <1.0 | 5 | ug/L | No |
| Azinphos-methyl | January 13 | <2.0 | 20 | ug/L | No |
| Benzene | January 13 | <0.10 | 1 | ug/L | No |
| Benzo(a)pyrene | January 13 | <0.0050 | 0.01 | ug/L | No |
| Bromoxynil | January 13 | <0.50 | 5 | ug/L | No |
| Carbaryl | January 13 | <5.0 | 90 | ug/L | No |
| Carbofuran | January 13 | <5.0 | 90 | ug/L | No |
| Carbon Tetrachloride | January 13 | <0.10 | 2 | ug/L | No |
| Chlorpyrifos (Dursban) | January 13 | <1.0 | 90 | ug/L | No |
| Diazinon | January 13 | <1.0 | 20 | ug/L | No |
| Dicamba | January 13 | <1.0 | 120 | ug/L | No |
| 1,2-Dichlorobenzene | January 13 | <0.20 | 200 | ug/L | No |
| 1,4-Dichlorobenzene | January 13 | <0.20 | 5 | ug/L | No |
| 1,2-Dichloroethane | January 13 | <0.20 | 5 | ug/L | No |
| 1,1-Dichloroethylene (vinylidene chloride) | January 13 | <0.10 | 14 | ug/L | No |
| Dichloromethane | January 13 | <0.50 | 50 | ug/L | No |
| 2,4 Dichlorophenol | January 13 | <0.25 | 900 | ug/L | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | January 13 | <1.0 | 100 | ug/L | No |
| Diclofop-methyl | January 13 | <0.90 | 9 | ug/L | No |
| Dimethoate | January 13 | <2.5 | 20 | ug/L | No |
| Diquat | January 13 | <7.0 | 70 | ug/L | No |
| Diuron | January 13 | <10 | 150 | ug/L | No |
| Ethylbenzene | January 13 | <0.10 | 140 | ug/L | No |
| Glyphosate | January 13 | <10 | 280 | ug/L | No |
| Haloacetic Acids (HAA) | Jan 13 Jan 13 lab dup Apr 6 Jul 13 Oct 19 | 5.6 5.5 13 25 15 | 80 | ug/L | No |
| Running Annual Average: | | 14.6 | | | |
| Malathion | January 13 | <5.0 | 190 | ug/L | No |
| 2 Methyl-4-chlorophenoxyacetic acid (MCPA) | January 13 | <10 | 100 | ug/L | No |
| Metolachlor | January 13 | <0.50 | 190 | ug/L | No |
| Metribuzin (Sencor) | January 13 | <5.0 | 80 | ug/L | No |
| Monochlorobenzene | January 13 | <0.10 | 80 | ug/L | No |
| Paraquat | January 13 | <1.0 | 10 | ug/L | No |
| Pentachlorophenol | January 13 | <0.50 | 60 | ug/L | No |
| Phorate | January 13 | <0.50 | 2 | ug/L | No |
| Picloram | January 13 | <5.0 | 190 | ug/L | No |
| Polychlorinated Biphenyls(PCB) | January 13 | <0.05 | 3 | ug/L | No |
| Prometryne | January 13 | <0.25 | 1 | ug/L | No |
| Simazine | January 13 | <1.0 | 10 | ug/L | No |
| Terbufos | January 13 | <0.50 | 1 | ug/L | No |
| Tetrachloroethylene | January 13 | <0.10 | 10 | ug/L | No |
| 2,3,4,6-Tetrachlorophenol | January 13 | <0.50 | 100 | ug/L | No |

| | | | | | |
|--------------------------------|-------------------------------------|----------------------------|-----|------|----|
| Trihalomethanes (THM) | Jan 13 Apr 6 Jul 13 Oct 19 | 23 26.4 45.7 30.7 | 100 | ug/L | No |
| Running Annual Average: | | 31.5 | | | |
| Toluene | January 13 | <0.20 | 60 | ug/L | No |
| Triallate | January 13 | <1.0 | 230 | ug/L | No |
| Trichloroethylene | January 13 | <0.10 | 5 | ug/L | No |
| 2,4,6-Trichlorophenol | January 13 | <0.50 | 5 | ug/L | No |
| Trifluralin | January 13 | <1.0 | 45 | ug/L | No |
| Vinyl Chloride | January 13 | <0.20 | 1 | ug/L | No |
| Xylenes | January 13 | <0.10 | 90 | ug/L | No |

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

| Parameter | Result Value | Unit of Measure | Date of Sample |
|-----------|--------------|-----------------|----------------|
| None | | | |

Summary of additional voluntary sampling and testing during this reporting period.

| Parameter | Sample Date | Result: Raw – Before Treatment | Result: Point of Entry | Unit of Measure |
|-------------|-------------|--------------------------------------|---------------------------|--------------------|
| Microcystin | May 25 | <0.150 | <0.150 | ug/L |
| | Jun 01 | <0.150 | <0.150 | |
| | Jun 08 | <0.150 | <0.150 | |
| | Jun 15 | <0.150 | <0.150 | |
| | Jun 22 | <0.150 | <0.150 | |
| | Jun 29 | <0.150 | <0.150 | |
| | Jul 06 | <0.150 | <0.150 | |
| | Jul 13 | <0.150 | <0.150 | |
| | Jul 20 | <0.150 | <0.150 | |
| | Jul 27 | <0.150 | <0.150 | |
| | Aug 04 | <0.150 | <0.150 | |
| | Aug 10 | <0.150 | <0.150 | |
| | Aug 17 | <0.150 | <0.150 | |
| | Aug 24 | <0.150 | <0.150 | |
| | Aug 31 | <0.150 | <0.150 | |
| | Sept 08 | <0.150 | <0.150 | |
| | Sept 14 | <0.150 | <0.150 | |
| | Sept 21 | <0.150 | <0.150 | |
| | Sept 28 | <0.150 | <0.150 | |
| | Oct 05 | <0.150 | <0.150 | |
| Oct 13 | <0.150 | <0.150 | | |
| Oct 19 | <0.150 | <0.150 | | |
| Oct 26 | <0.150 | <0.150 | | |