

2017 Compliance Report for the Dresden Water Pollution Control Plant Public Utilities Commission for the Municipality of Chatham-Kent

The Dresden Water Pollution Control Plant provides treatment of wastewater for approximately 2,500 residents of Dresden. Wastewater is collected and transported to the plant by gravity through the sanitary sewer system. As such, there are no sanitary pump stations located in Dresden.

The Dresden Water Pollution Control Plant is an Extended Aeration Plant with chemical phosphorus removal and final effluent disinfection. The plant was built in 1976 with a maximum design flow of 4,546m³/day. The plant discharges final effluent to the Sydenham River.

The existing treatment system includes the following processes:

- Raw sewage pumping
- Screening collection and removal
- Aerated Grit System
- Aeration Tanks
- Chemical phosphorus removal
- Settling Clarifiers
- Chlorine disinfection of final effluent
- Sludge collection and pumpage
- Sludge holding lagoons

Sludge from the holding lagoons is applied to agricultural land in the spring and fall each year.

C of A # 8101-7QHKYR

Non-compliance issues during 2017:

There were no non-compliance issues.

2017 Compliance Report for the Dresden Water Pollution Control Plant

Plant Rated Capacity: 4,546 m³/day

Total sewage flow to the works during a calendar year divided by the number of days during which sewage was flowing to the works that year

Month	Total Monthly Influent Flow m ³	Avg Daily Influent Flow /Month m ³ /day	Avg Daily Influent Flow/Year m ³ /day	% of Plant Capacity	CBOD5 mg/L	pH	Total P mg/L	Total S.S. mg/L	Total Cl2 mg/L	E.coli
Limits	none	none	4,546	100	25	6.0 - 9.5	1.0	25		200
Objectives	none	none	4,546	100	15	6.0 - 9.5	0.8	15		
Jan	41,848	1,350			2.4	7.31	0.15	9.0	0.73	10.84
Feb	36,287	1,296			2.0	7.63	0.14	4.5	0.71	10.00
Mar	47,535	1,533			2.8	7.55	0.32	11.3	0.77	57.49
Apr	58,289	1,943			2.5	7.54	0.28	5.8	0.84	18.99
May	50,239	1,621			2.4	7.83	0.10	4.4	0.79	10.00
Jun	38,517	1,284			2.0	7.65	0.09	2.0	0.82	10.00
Jul	39,115	1,262			2.0	7.92	0.08	2.2	0.57	13.20
Aug	35,395	1,142			2.0	7.56	0.09	2.8	0.64	13.16
Sep	100,465	3,349			2.0	7.79	0.16	4.0	0.65	27.11
Oct	74,366	2,399			2.0	8.34	0.08	2.8	0.63	17.19
Nov	45,841	1,528			2.0	7.73	0.04	1.5	0.85	14.95
Dec	33,716	1,088			2.0	7.71	0.07	2.3	0.66	10.00
Year			1,648	36%						
	Yearly Total Flow m³	Yearly Maximums								
	601,613	3,349			2.8	8.34	0.32	11.3	0.85	57.49