

**THE CORPORATION OF THE MUNICIPALITY OF CHATHAM-KENT  
CLEARVILLE PARK WASTEWATER TREATMENT PLANT**

**2018 PERFORMANCE REPORT**

**January 1 to December 31, 2018**

**Amended Certificate of Approval # 7957-762JAZ**

## **Plant Description**

The Clearville Park Wastewater Treatment Plant provides treatment of wastewater for Clearville Park. Wastewater is collected by a separate sanitary sewer system and conveyed to two Waterloo Bio-filter treatment units. The treated wastewater is subsequently discharged to Clear Creek.

During April 2005, the PUC was contracted by the Municipal Parks and Recreation Department to operate the plant.

This tertiary wastewater treatment system has a rated capacity of 30 m<sup>3</sup>/ day, and services a seasonal campground.

The present treatment system consists of:

- Two septic tanks
- One bio-filter dosing tank and submersible pumps
- Two Waterloo Bio-filter treatment units
- UV disinfection

The effluent outfall pipe discharges to the Clear Creek.

## **REPORTING REQUIREMENTS UNDER CERTIFICATE OF APPROVAL # 7957-762JAZ**

### **Summary and Interpretation of Monitoring and Comparison to the Effluent Limits & Objectives: Condition 9 (2) (a) (b)**

Tables 1 and 2 on the following pages outlines monthly average results of parameters tested compared to the limits outlined in the Certificate of Approval Tables 3 – Effluent Objectives and Table 2 - Effluent Limits.

An exceedance of the average monthly concentration effluent limit for Total Ammonia occurred for the month July. The Effluent Limit monthly average concentration for Total Ammonia is 5 mg/L. The monthly average Total Ammonia concentration for July was 7.64 mg/L. The plant experienced high influent sewage flows July 28 & 29 due to heavy rainfall combined with increased weekend traffic at the campground. This resulted in an elevated total ammonia concentration on July 30 as well as for the monthly average.

The following criteria exceeded the effluent objectives outlined in the Certificate of Approval Table 3 Effluent Objectives:

Total Phosphorus concentration: June, July, August, September, October

Total Ammonia concentration: July, August

Total Suspended Solids concentration: May, August

Continuing optimization of chemical feed was practiced throughout the year with the goal of achieving effluent objectives.

***Success and Adequacy of the Works***

During the reporting period, the annual average daily flow was 8.60 m<sup>3</sup>/day, which represents approximately 29% of the rated capacity of 30 m<sup>3</sup>/day. The maximum daily flow was 46 m<sup>3</sup>/day, which is 153% of the rated capacity.

There were no flow exceedances based on the Average Daily Flow during this reporting period.

Overall, the Clearville Park Wastewater Treatment Plant performed well for this reporting period.

**Table 1: Summary of Monitoring Data and Comparison to Effluent Limits & Objectives – Concentrations**  
as well as rated capacity to the sewage works

**Plant Rated Capacity (m<sup>3</sup>/day): 30**

**Total flow during calendar year divided by the number of days during which sewage was flowing (measured on the effluent pipe discharging to the outfall)**

Month	Total Monthly Flow m <sup>3</sup>	Avg Daily Flow /Month m <sup>3</sup> /day	Avg Daily Flow /Year m <sup>3</sup> /day	% of Plant Capacity	CBOD <sub>5</sub> mg/l	Total S.S. mg/l	Total Ammonia mg/l	Total P mg/l	pH	E.Coli /100ml CFU
Limits	None	None	30	100	15	15	5.0	0.7	6.0 – 9.5	200
Objectives	None	None	30	100	10	10	3.0	0.3	6.0 – 9.5	100
Jan										
Feb										
Mar										
Apr										
May	245.0	7.90			2	13	0.8	0.16	7.99	13
Jun	167.0	5.57			2	1	1.7	0.40	8.18	10
Jul	257.4	8.30			3	2	7.6	0.48	7.87	11
Aug	324.9	10.45			2	13	3.9	0.65	7.86	13
Sept	245.2	8.17			2	2	2.7	0.69	8.03	10
Oct	198.2	11.66			2	2	0.69	0.42	7.77	16
Nov										
Dec										
Year			8.60	29%						
	Yearly Total Flow m <sup>3</sup>	Yearly Maximums								
	1436.7	11.66	8.60	29%	3	13	7.6	0.69	8.18	16

**Table 2: Summary of Monitoring Data and Comparison to Effluent Limits – Loadings**

<b>Date</b>	<b>Avg Daily Effluent Flow /Month m<sup>3</sup>/day</b>	<b>CBOD<sub>5</sub> kg/day</b>	<b>Total S.S. kg/day</b>	<b>Total Ammonia kg/day</b>	<b>Total P kg/day</b>
<b>Limits</b>	<b>30</b>	<b>0.45</b>	<b>0.45</b>	<b>0.15</b>	<b>0.021</b>
<b>Jan</b>					
<b>Feb</b>					
<b>Mar</b>					
<b>Apr</b>					
<b>May</b>	7.90	0.02	0.10	0.01	0.001
<b>Jun</b>	5.57	0.01	0.01	0.01	0.002
<b>Jul</b>	8.30	0.02	0.02	0.06	0.004
<b>Aug</b>	10.44	0.02	0.14	0.04	0.007
<b>Sep</b>	8.17	0.02	0.02	0.02	0.006
<b>Oct</b>	11.66	0.02	0.02	0.01	0.005
<b>Nov</b>					
<b>Dec</b>					
		<b>Yearly Maximums</b>			
		0.02	0.14	0.06	0.007

**Summary of Maintenance Activities:  
Condition 9 (2)(c)**

Routine maintenance was performed throughout the reporting period. Chatham-Kent PUC utilises an electronic preventative maintenance program to track preventative maintenance. In addition to the routine maintenance, the following additional maintenance activities and equipment replacement was completed for the reporting period:

No significant expenditures incurred for additional maintenance activities and equipment replacement during the reporting period.

**Operating Problems and Corrective Action:  
Condition 9 (2)(d)**

There were no significant operating problems encountered during this reporting period.

**Quality Assurance and Control Measures:**

The Chatham-Kent Public Utilities Commission followed a sampling schedule developed in accordance with the Certificate of Approval and applicable regulations for this reporting period.

Composite chemistry samples of the effluent were collected using an auto sampler. Chemistry samples were submitted weekly to an accredited laboratory for analysis of CBOD<sub>5</sub>, Total Suspended Solids, Total Kjeldhal Nitrogen, Total Phosphorus and Total Ammonia Nitrogen, Alkalinity, pH, Nitrite and Nitrate.

Bacteriological samples of the effluent were collected weekly according to the Sampling Program. Bacteriological samples were submitted weekly to an accredited laboratory for analysis.

**Calibration and Maintenance on Effluent Monitoring Equipment**

Monitoring equipment calibration/verification report(s) included for the following:

- Effluent flow meter

**Community Complaints:**

There were no Customer Complaints received during the reporting period.

**By-pass, Spill, or Abnormal Discharge Events:**

There were no by-pass, spill, or abnormal discharge events for the reporting period.

**Other Information the District Manager Requires:**

No other information was required from the District Manager during this reporting period.

## **APPENDIX A**

### **Monthly and Yearly Operational Data Summary for the Reporting Period**

# CHATHAM-KENT PUC

## Clearville Park Wastewater Treatment Plant Operational Data Yearly Summary

Works # 120002843

YEAR 2018 2018

DESCRIPTION	2018												TOTAL	AVERAGE	HIGH	LOW	MOE Objective	Non-Compliance	
	JANUARY	FEBRUARY	MARCH	APRIL	MAY	JUNE	JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER							
<b>FINAL EFFLUENT FLOW DATA</b>																			
CLEARVILLE FLOW MONTH TOTAL cu. m.					245,000	167,000	257,400	323,900	245,200	198,200				1436,700					
CLEARVILLE FLOW MONTH AVG. cu. m.					7,903	5,567	8,303	10,440	8,173	11,659				8,674	11,659	5,567		30 / day	
CLEARVILLE FLOW MONTH PEAK cu. m.					46,000	13,000	28,100	41,400	22,900	29,000				46,000	13,000				

FINAL EFFLUENT CHEMICAL	UNIT	JANUARY	FEBRUARY	MARCH	APRIL	MAY	JUNE	JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	TOTAL	AVERAGE	HIGH	LOW	MOE Objective	Non-Compliance
AMMONIA	mg/l					0.75	1.65	7.64	3.93	2.65	0.69								5
AMMONIA	kg/day					0.01	0.01	0.06	0.04	0.02	0.01								0.15
CBOD5	mg/l					2	2	3	2	2	2								15
CBOD5	kg/day					0.02	0.01	0.02	0.02	0.02	0.02								0.45
TKN	mg/l					1.81	3.48	8.50	6.45	3.90	2.50								6.9-9.5
pH						7.99	8.18	7.87	7.86	8.03	7.77								0.7
TOTAL P	mg/l					0.16	0.40	0.48	0.65	0.69	0.42								0.021
TOTAL P	kg/day					0.001	0.002	0.004	0.007	0.006	0.005								15
SS	mg/l					13	1	2	13	2	2								0.45
SS	kg/day					0.10	0.01	0.02	0.14	0.02	0.02								
ALKALINITY	mg/l					353	713	498	455	525	433								
NITRITE	mg/l					0.015	0.086	0.941	0.703	0.365	0.135				0.374	0.941	0.015		
NITRATE	mg/l					16.90	61.15	73.90	53.20	81.55	45.20				55.3	81.6	16.9		

FINAL EFFLUENT (BACTERIOLOGICAL)	UNIT	JANUARY	FEBRUARY	MARCH	APRIL	MAY	JUNE	JULY	AUGUST	SEPTEMBER	OCTOBER	NOVEMBER	DECEMBER	TOTAL	AVERAGE	HIGH	LOW	MOE Objective	Non-Compliance	
E. COLI.	# / 100ml					13	10	11	10	10	16									200

Facility Begin Operation on May 4, 2018  
Effluent Flow halted on Oct. 17, 2018



## **APPENDIX B**

### **Calibration Reports for the Reporting Period**

AS FOUND CERTIFICATION  
 FORWARD FLOW DIRECTION

PASS

CLIENT DETAIL		EQUIPMENT DETAIL	
CUSTOMER	Municipality of Chatham-Kent	[MUT] MANUFACTURER	ENDRESS & HAUSER
CONTACT	Larry Garside	MODEL	Prosonic 91W
	Senior Operator - Ridgetown	CONVERTER S/N:	C3014E16000
	4 Tecumseh Street	FUSE	Pull Plug on Unit
	Ridgetown, Ontario		
	NOP 2C0	PLANT ID	CLWW Plant
	t: 519-674-2802	METER ID	Final Effluent Flow
	c: 519-358-6661	FIT ID	n/a
	e: larryg@chatham-kent.ca	CLIENT TAG	n/a
		OTHER	
VER. BY - FM	Paris Machuk	GPS COORDINATES	N42 27.321 W081 41.849
Quality Management Standards Information - Reference equipment and instrumentation used to conduct this verification test is found in our AC- QMS document at the time this test was		VERIFICATION DATE	March 27, 2018
		CAL. FREQUENCY	Annual
		CAL. DUE DATE	March, 2019

PROGRAMMING PARAMETERS			FORWARD TOTALIZER INFORMATION		
DIAMETER (DN)	mm	100	AS FOUND	13256.3	M3
F.S. FLOW - MAG	LPS	78.538	AS LEFT	13276.3	M3
F.S. RANGE - O/P	LPS	50.000	DIFFERENCE	20	M3
TUBE k-FACTOR		1.0000			
TUBE zero		0			
			AS FOUND CERTIFICATION TEST	Yes	
			FORWARD FLOW DIRECTION	Yes	
			ALLOWABLE [%] ERROR	5	
			<b>COMPONENTS TESTED</b>		
			CONVERTER DISPLAY	yes	
			mA OUTPUT	no	
			TOTALIZER	yes	
			ACCURACY BASED ON [% o.r.]	yes	
			ERROR DOCUMENTED IN THIS REPORT; BASED ON % o.r.		

FLOW TUBE SIMULATION						
	0.0	12.5	25.0	37.5	50.0	LPS
	0.0	15.9	31.8	47.7	63.7	% F.S. Flow
	0.0	25.0	50.0	75.0	100.0	% F.S. Range
REF. FLOW RATE	0.000	12.500	25.000	37.500	50.000	LPS
MUT [Reading]	0.000	12.511	25.027	37.537	50.045	LPS
MUT [Difference]	0.000	0.011	0.027	0.037	0.045	LPS
MUT [% Error]	n/a	0.09	0.11	0.10	0.09	% O.R
mA OUTPUT						
MUT [Reading]	min. 4 mA					
MUT [Difference]	max. 20 mA					
MUT [% Error]						
TOTALIZER - REF. FLOW RATE					50.000	LPS
TOTALIZER [MUT]					4	M3
TEST TIME					79.93	SECONDS
CALC. TOTALIZER					3.997	M3
ERROR					0.09	%

COMMENTS	QUALITY MANAGEMENT STANDARDS INFO.	RESULTS		
		TEST	AVG % o.r.	PASS FAIL
Note: mA output not used therefore not checked.	[QMS] INFORMATION IDENT. ID #			
	[REFERENCE] FTS E&H (FC) 1			
	PROCESS METER PM 2	DISPLAY	0.10	PASS
	ANALOG METER AM n/a	mA OUTPUT	N/A	N/A
	STOP WATCH SW Yes	TOTALIZER - R	0.09	PASS

This report reflects the test results of the overall accuracy for the above flow converter using the specified manufacturers flow tube simulator to within the specified tolerance as identified within this report.