

**PUBLIC UTILITIES COMMISSION
FOR THE MUNICIPALITY OF CHATHAM-KENT
MITCHELL'S BAY LAGOONS**

2018 PERFORMANCE REPORT

January 1 to December 31, 2018

Amended Certificate of Approval # 1-502-77-006

Plant Description

The Mitchell's Bay Sewage Lagoon System provides treatment of wastewater for approximately 500 residents of the Mitchell's Bay community. Wastewater is collected and pumped to the sewage lagoon system from one sanitary pump station.

The Mitchell's Bay Sewage Lagoon System was built in 1977 with a maximum design flow of 509 m³/day. This sewage treatment facility consists of 3 treatment cells each 5 acres in size. Final effluent is discharged to Rankin Creek in the spring and fall if required.

REPORTING

Summary and Interpretation of Monitoring and Comparison to the Effluent Limits

The following Ministry Procedures / Guidelines apply:

Procedure F-5-1:	Minimum effluent limits BOD ₅ , Suspended Solids
Guideline F-8:	Effluent limits Phosphorus
Procedure F-10-1:	Minimum monitoring program
Table C-1:	Monitoring, recording and reporting bypasses

Table 1 on the following page outlines monthly average results of parameters tested compared to the Effluent Guidelines & Effluent Design Objectives set out in one or more of the above Ministry Procedures /Guidelines.

Success and Adequacy of the Works

During the reporting period, the annual average daily flow was 154 m³/day, which represents approximately 30% of the rated capacity of 509 m³/day.

Overall, the Mitchell's Bay Lagoons performed well for this reporting period

Table 1: Summary of Monitoring Data and Comparison to Effluent Guidelines & Effluent Design Objectives - Concentrations
as well as rated capacity to the sewage works

Rated capacity: 509 m³/day

Total sewage flow to the works during a calendar year divided by the number of days during which sewage was flowing to the works that year

Month	Total Monthly Influent Flow m ³	Avg Daily Influent Flow /Month m ³ /day	Avg Daily Influent Flow/Year m ³ /day	% of Rated Capacity	BOD ₅ mg/L	Total S.S mg/L	Total P mg/L
Limits: without batch TP removal	None	None	509	100	30	40	1.0
Objectives: without batch TP removal	None	None	509	100	25	30	0.5 - 1.0
Limits: with batch TP removal	None	None	509	100	25	25	1.0
Objectives: with batch TP removal	None	None	509	100	15	20	0.5 - 1.0
Jan	3,836	124					
Feb	5,968	213					
Mar	4,811	155			10	26	0.74
Apr	6,422	214					
May	6,554	211					
Jun	4,572	152			3	4	0.66
Jul	4,065	131					
Aug	4,055	131					
Sep	3,489	116					
Oct	4,156	134					
Nov	4,606	159					
Dec	3,698	119					
Year			154	30%			
	Yearly Total Flow m³	Yearly Maximums					
	56,232	214			10	26	0.74

Batch TP removal was not performed for the February to March discharge period.

Batch TP removal was performed for the June discharge period.

Operating Problems and Corrective Action:

There were no significant operating problems encountered during this reporting period.

Summary of Maintenance Activities:

Routine maintenance was performed throughout the reporting period. Chatham-Kent PUC utilizes the electronic preventative maintenance program to track preventative maintenance. In addition to routine maintenance, the following additional maintenance activity was completed for the reporting period: none.

No significant expenditures incurred for additional maintenance activities and equipment replacement during the reporting period.

Quality Assurance and Control Measures:

The Chatham-Kent Public Utilities Commission followed a sampling schedule developed in accordance with the Certificate of Approval and applicable regulations for this reporting period.

Raw chemistry samples were collected and submitted monthly to an accredited laboratory for analysis of BOD₅, Total Suspended Solids, pH and Total Phosphorus.

During reporting periods where there is discharge, the following sampling program is followed: Final Effluent chemistry samples are collected and submitted during discharge periods to an accredited laboratory for analysis of Total BOD, Total Suspended Solids, Total Kjeldahl Nitrogen, Total Phosphorus, Total Ammonia as N, Alkalinity, pH, Nitrite and Nitrate, Hydrogen Sulphide.

Bacteriological samples of the effluent are collected during discharge periods according to the Sampling Program. Bacteriological samples are submitted during discharge periods to an accredited laboratory for analysis.

In house samples were analyzed by a licensed operator for pH and temperature.

Calibration and Maintenance on Monitoring Equipment

Monitoring equipment calibration/verification report(s) included for the following:

- Influent flow meter

Community Complaints:

There were no Customer Complaints received during the reporting period.

By-pass, Spill, or Abnormal Discharge Events:

There were no by-pass, spill, or abnormal discharge events for the reporting period.

Other Information the District Manager Requires:

No other information was required from the District Manager during this reporting period.

APPENDIX A

Yearly Operational Data Summary for the Reporting Period

CELL TREATMENT	
Cell Number	
Date Treated	
Chemical Used	
Volume of Chemical	m ³
Volume Treated	1000 m ³
Dosage Rate	mg/L

LAGOON DISCHARGE

Cell Number	3	flow/ hour: 94.31m3
Date/Time Start	22-Feb-18 10:00	
Date/Time Stop	05-Mar-18 9:00	Mar Flow: 9902.55
Duration (hours)	264	Mar Hours: 105
Total Discharge Flow 1000m ³	24.90	Feb flow: 14995.29
		Feb Hour: 159
	Total Hrs =	
	Total Flow =	24,900 m ³

EFFLUENT SAMPLES	Lab Test Results										Field Test Results							
	Ammonia mg/L	B.O.D.5 mg/L	TKN mg/L	pH	T.P. mg/L	T.S.S. mg/L	H2S mg/L	ALK CaCO3	Nitrite NO2 mg/L	Nitrate NO3 mg/L	E.Coli cfu/100 ml	pH	D.O. mg/L	Temp. °C	CBOD 5 mg/L	Federal (15°C) pH 15°C	Un-ionized Ammonia mg/L	T.S.S. mg/L
22-Feb-2018	0.26	2.00	0.71	7.56	0.15	5.00		34.00	0.10	0.34	10							5.00
23-Feb-2018	0.22	8.00	1.00	7.76	0.35	13.00		51.00	0.01	0.30	30				6.00			13.00
26-Feb-2018	3	12.00	5.10	7.90	1.30	26.00		170.00	0.01	0.10	50				12.00			26.00
28-Feb-2018	2.40	14.00	4.00	7.84	1.00	25.00		170.00	0.01	0.10	10				13.00			25.00
05-Mar-2018	2.5	15.00	4.3	7.77	0.88	62.00		190.00	0.01	0.10	10				15.00			62.00
Average	1.68	10.20	3.02	7.77	0.74	26.20	#DIV/0!	123.00	0.03	0.19	22.00	#DIV/0!	#DIV/0!	#DIV/0!	11.50	#DIV/0!	#DIV/0!	26.20

LAGOON DISCHARGE

Cell Number	3	flow/ hour: 81.78
Date/Time Start	12-Jun-18 7:45	June Flow: 11879 m3
Date/Time Stop	18-Jun-18 9:00	June Hours: 145.25 hrs
Duration (hours)	11.88	
Total Discharge Flow 1000m ³		Total Hrs = 145.25
		Total Flow m ³ = 11879

EFFLUENT SAMPLES	Lab Test Results										Field Test Results							
	Ammonia mg/L	B.O.D.5 mg/L	TKN mg/L	pH	T.P. mg/L	T.S.S. mg/L	H2S mg/L	ALK CaCO3	Nitrite NO2 mg/L	Nitrate NO3 mg/L	E.Coli cfu/100 ml	pH	D.O. mg/L	Temp. °C	CBOD 5 mg/L	Federal (15°C) pH 15°C	Un-ionized Ammonia mg/L	T.S.S. mg/L
12-Jun-2018	7.0	2.00	8.0	7.85	0.57	4.00		190.00	0.01	0.10	20	6.83	7.85		2.00		0.022	4.00
14-Jun-2018	7.5	5.00	7.9	7.89	0.52	3.00		190.00	0.02	0.10	20	7.60	7.89		5.00		0.120	3.00
18-Jun-2018	8.2	3.00	8.7	8.0	0.90	6		200.00	0.01	0.10	130	88.00		2.00		0.150	6	
Average	7.57	3.33	8.20	7.91	0.66	4.33	#DIV/0!	193.33	0.01	0.10	56.67	34.14	#DIV/0!	3.00		0.10	0.10	4.33

Month Average	
BOD5	TSS
	TP

Total Effluent Flow 2018

36,779 m³

Average CBOD: 7.25
Average TSS: 15.27
Number of days: 19

Annual Average Daily Effluent Flow 2019

Acute Lethality **101** m³

APPENDIX B

Calibration Reports for the Reporting Period

AS FOUND CERTIFICATION

PASS

CLIENT DETAIL

CUSTOMER Municipality of Chatham-Kent - North
CONTACT Brian Patrick
Senior/Chief Operator, OWRC Wallaceburg Pollution Control Plant
795 Gillard Street
Wallaceburg, ON N8A 5G7
T: 519-627-1211
C: 519-354-5664
E: brianpa@chatham-kent.ca

EQUIPMENT DETAIL
MODEL FEV125 WaterMaster
SENSOR SERIAL NUMBER 3K620000200759
CONVERTER SERIAL NUMBER 3K620000200759
SENSOR SIZE (DN) 100

PLANT ID Mitchell's Bay Pumping Station
METER ID Station Flow Meter
FIT ID N/A
CLIENT TAG N/A
OTHER N/A
GPS COORDINATES N/A

VER. BY - FM Paris Machuk

Quality Management Standards Information -
Reference equipment and instrumentation used to
conduct this verification test is found in our AC-
QMS document at the time this test was

VERIFICATION DATE February 01, 2018
CAL. FREQUENCY Annual
CAL. DUE DATE February, 2019

SENSOR INFORMATION

Q3 l/s 69.44
CALIBRATION ACCURACY OIML Class 2
SENSOR CAL. ACCURACY % 89.3
mm/sec-2
~ 11
DATE OF MANUFACTURE Sept 25, 2015
RUN HOURS d/h/m 583/21/35

TRANSMITTER INFORMATION

APPLICATION VERSION v01.06.00 03/03/151
MSP VERSION 01.00.00
DATE OF MANUFACTURE Sept 25, 2015
RUN HOURS d/h/m 859/10/9
ALLOWABLE TOLERANCE % 5.0

CURRENT OUTPUT

OUTPUT TEST	4.00	20.00	READING mA	ERROR %	PASS FAIL
4.0 mA	4.00	3.995	-0.12	PASS	
12.0 mA	12.00	11.974	-0.22	PASS	
20.0 mA	20.00	19.981	-0.09	PASS	

PULSE OUTPUT

OUTPUT TEST	READING mA	ERROR %	PASS FAIL
OUTPUT 1, Hz 500	N/A	N/A	N/A
OUTPUT 1, Hz 250	N/A	N/A	N/A
OUTPUT 2, Hz 100	N/A	N/A	N/A
OUTPUT 2, Hz 50	N/A	N/A	N/A

VERIFICATION HISTORY

OIML Accuracy Alarms 0

TOTALIZER INFORMATION

FORWARD 81795.64 m3
REVERSE 16.85 m3
NET 81778.79 m3

SENSOR DATA

COIL CURRENT 179.9 mA
COIL INDUCTANCE 222.6 mH
COIL SHIFT -0.2 %
COIL/LOOP RESISTANCE 37.7 ohm

TRANSMITTER DATA

TX GAIN - ADJUSTMENT 0.1 %

VeriMASTER INFORMATION

VERSION 01.00.01
LIMIT VERSION 01.00.01

CONFIGURATION SETTINGS

MAINS/FREQUENCY 60 Hz
QMAX 50 l/s
PULSES/UNIT 120
PULSES LIMIT FREQUENCY 1200 Hz
SENSOR USER SPAN 100 %
ZERO 0 mm/s
USER FLOW CUTOFF 1 %
HYSTERESIS 20 %
METER MODE Normal Operation

COMMENTS

QUALITY MANAGEMENT STANDARDS INFO.

[QMS] INFORMATION	IDENT.	ID #
[REFERENCE] FTS	ABBWM	1
PROCESS METER	DMM	2

The information contained within this report was produced by "VeriMASTER - Flow Meter Verification Report". The AS LEFT information is the same as the AS FOUND information within this report. If changes have been made relative to the accuracy of the calibration, an AS LEFT certificate will be issued.