

**PUBLIC UTILITIES COMMISSION
FOR THE MUNICIPALITY OF CHATHAM-KENT
WHEATLEY WATER POLLUTION CONTROL PLANT**

2018 PERFORMANCE REPORT

January 1 to December 31, 2018

Certificate of Approval # 3-1602-90-927 and 1-822-83-006

Plant Description

The Wheatley Water Pollution Control Plant is located at 289 First Concession Line in Wheatley. The facility was constructed in 1985 with further plant upgrades in the 1990s. Four sewage pump stations serve the facility. The Wheatley Water Pollution Control Plant C of A limits the average daily flow to 2,752 m³/day with a peak flow capacity of 8,500 m³/day. The plant effluent is discharged to Lake Erie.

The existing treatment system uses the following treatment process:

- Raw sewage pumping
- Aeration tanks
- Aerobic digesters
- Sludge storage tank
- Phosphorus Removal System
- Final clarifiers
- Chlorine Contact Chamber with Chlorine for Disinfection

REPORTING REQUIREMENTS UNDER CERTIFICATE OF APPROVAL # 3-1602-90-927 and 1-822-83-006

Summary and Interpretation of Monitoring and Comparison to the Effluent Limits & Objectives: Special Terms and Conditions

Tables 1 and 2 on the following pages outline monthly average results of parameters tested compared to the limits and objectives outlined in Provincial Guideline F-8 and the Certificate of Approval.

No criteria were exceeded during this reporting period the effluent limits based on the average annual effluent results.

No criteria were exceeded during this reporting period the effluent objectives based on the average annual effluent results.

Success and Adequacy of the Works

During the reporting period, the annual average daily flow was 1,934 m³/day, which represents approximately 70% of the rated capacity of 2,752 m³/day. The maximum daily flow of 5,339 m³/day is 63% of the peak flow capacity of 8,500 m³/day.

Overall, the Wheatley Water Pollution Control Plant performed well over the operating period.

Table 2: Summary of Monitoring Data and Comparison to Effluent Limits & Objectives – Waste Loadings

(Avg Daily Flow, BOD, S.S and Total P calculated by 12 month arithmetic mean)

Month	Avg Daily Effluent Flow /Year m ³ /day	BOD5 Kg/day	Total S.S. Kg/day	Total P Kg/day	Total Ammonia kg/day
Limits	None	68.8	68.8	2.75	none
Objectives	None	41.3	41.3	2.75	13.8

Effluent Waste Loading over any consecutive 12 month period (CofA 3-1602-90-927) reported in kg/d

	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18
BOD	4.1	4.5	4.5	4.5	4.6	4.5	4.5	4.5	4.4	5.2	5.0	5.6
Total S.S.	12.58	13.36	13.72	14.25	14.90	14.76	14.74	15.48	15.50	15.20	15.00	16.89
Total P.	0.93	0.94	0.73	0.94	0.97	0.97	0.90	0.84	0.76	0.71	0.69	0.72
Total Ammonia	0.63	0.64	0.67	0.66	0.64	0.58	0.56	0.54	0.42	0.65	0.67	0.72

Operating Problems and Corrective Action:

There were no significant operating problems encountered during this reporting period.

Summary of Maintenance Activities:

Routine maintenance was performed throughout the reporting period. Chatham-Kent PUC utilises the electronic preventative maintenance program to track preventative maintenance. In addition to the routine maintenance, the following additional maintenance activities and equipment replacement was completed for the reporting period:

- New Transfer Sludge Piping \$12,904
- Clarifier Scrapper repairs 16,249
- Pump Station #1 and #6 repairs 18,664
- Annual generator maintenance 2,248
- Pump #3 from station #1 rail guide replaced 558

Quality Assurance and Control Measures:

The Chatham-Kent Public Utilities Commission followed a sampling schedule developed in accordance with the Certificate of Approval and applicable regulations for this reporting period.

Composite chemistry samples of the raw flow were collected using an auto sampler. Chemistry samples were submitted weekly to an accredited laboratory for analysis of BOD₅, Total Suspended Solids, Total Kjeldhal Nitrogen, Total Phosphorus, Total Ammonia Nitrogen, and pH.

Composite chemistry samples of the effluent were collected using an auto sampler. Chemistry samples were submitted weekly to an accredited laboratory for analysis of BOD₅, CBOD, Total Suspended Solids, Total Kjeldhal Nitrogen, Total Phosphorus and Total Ammonia Nitrogen, pH, Nitrite and Nitrate and Unionized Ammonia.

Bacteriological samples of the effluent were collected weekly according to the Sampling Program. Bacteriological samples were submitted weekly to an accredited laboratory for analysis.

In house samples were analysed by a licensed operator for pH and temperature.

Calibration and Maintenance on Effluent Monitoring Equipment

All required probes and sensors are cleaned, maintained and/or calibrated on a monthly basis or as required by manufacturers' specifications.

Monitoring equipment calibration/verification report(s) included for the following:

- Influent flow meter
- Effluent flow meter
- Spectrophotometer
- pH meter

Sludge Management: Certificate of Approval 3-1602-90-927 Condition 5 (iii):

Overview of the Sludge Disposal Program:

Tabulation of the Quality and Quantity of Sludge for the Period Being Reported On

MONTH	DISPOSAL AREA	SLUDGE QUALITY	SLUDGE QUANTITY LAND APPLIED m³
July	574405 Ontario Inc. c/o Ken Koster 29164 Florence Road Zone TWP ON N0P 2K0	Within Ministry Guidelines	1,640
November	574405 Ontario Inc. c/o Ken Koster 29164 Florence Road Zone TWP ON N0P 2K0	Within Ministry Guidelines	640
Total			2,280

Sludge Handling For the Next Reporting Period:

1. Proposed Sludge Handling Method

The sludge production and sludge handling method for the coming reporting period is anticipated to be the similar to that of this reporting period.

2. Anticipated Disposal Area(s)

574405 Ontario Inc. c/o
Ken Koster
29164 Florence Road
Zone TWP ON
N0P 2K0

Community Complaints:

There were no Customer Complaints received during the reporting period.

By-pass, Spill, or Abnormal Discharge Events:

There was no by-pass, spill, or abnormal discharge events for the reporting period.

Other Information the District Manager Requires:

No other information was required from the District Manager during this reporting period.

APPENDIX A

Yearly Operational Data Summary for the Reporting Period

	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18	TOTAL	MAX	MIN	AVG
Raw Sewage Flow																
Total Flow 1000m ³	51.301	55.013	59.009	66.515	76.492	50.845	52.846	61.505	51.795	56.449	66.039	58.068	705.877	76.492	50.845	58.823
Average Daily Flow 1000m ³	1.655	1.965	1.904	2.217	2.467	1.695	1.705	1.984	1.727	1.821	2.201	1.873		2.5	1.7	1.9
Maximum Daily Flow 1000m ³	3.714	4.021	3.915	5.339	5.213	2.333	2.571	2.466	2.205	2.390	4.306	2.879		5.339	2.205	3.446
Raw Sewage Average																
Suspended Solids mg/L	115	173	733	139	220	248	214	250	675	185	232	368		733	115	296
BOD mg/L	78	87	295	117	131	131	159	130	167	159	283	148		295	78	157
Total P mg/L	4.4	2.4	26.9	2.7	6.7	5.0	5.9	5.4	4.5	4.1	4.7	6.3		26.9	2.4	6.6
TKN mg/L	23.8	19.0	34.3	22.6	29.5	27.3	30.8	26.0	28.0	25.4	30.0	22.0		34.3	19.0	26.6
Ammonia mg/L	16.6	11.4	19.0	11.5	18.3	19.0	21.6	17.8	21.0	20.2	16.5	11.8		21.6	11.4	17.1
pH	7.03	7.47	7.89	7.52	7.71	7.37	7.31	7.67	7.43	7.29	7.23	7.30		7.89	7.03	7.44
Temperature C	11.0	11.1	11.3	11.1	14.6	16.4	19.0	19.0	19.3	17.7	14.9	12.8		19.3	11.0	14.9
Final Effluent Average																
Final Effluent Total Flow 1000m ³	59.216	70.815	62.460	70.201	84.455	56.094	61.308	70.186	65.756	52.720	56.806	61.228	771.245	84.46	52.72	64.27
Final Effluent Avg Daily Flow 1000m ³	1.910	2.529	2.015	2.340	2.724	1.870	1.978	2.264	2.192	1.701	1.894	1.975		2.72	1.70	2.12
Suspended Solids mg/L	5	8	6	9	11	5	4	8	9	11	9	15		14.5	4.2	8.1
BOD mg/L	2	2	2	2	3	2	2	2	2	6	2	5		6	2	3
Total P mg/L	0.23	0.23	0.22	0.35	0.67	0.54	0.17	0.33	0.21	0.31	0.20	0.68		0.68	0.17	0.34
TKN mg/L	0.5	0.1	0.6	0.8	1.5	1.0	0.5	0.6	0.8	2.9	1.0	1.1		2.9	0.1	1.0
Nitrites mg/L	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.10	0.06	0.04	0.06	0.05		0.10	0.01	0.03
Nitrates mg/L	16.6	14.9	15.9	15.9	19.8	24.1	19.8	16.2	12.9	7.7	6.3	14.1		24.1	6.3	15.4
pH	6.48	6.99	7.20	6.80	6.93	6.66	6.46	7.01	6.96	6.85	6.76	6.76		7.20	6.46	6.82
Ammonia mg/L	0.07	0.05	0.19	0.10	0.09	0.05	0.06	0.16	0.19	2.21	0.28	0.36		2.21	0.05	0.32
Unionized Ammonia mg/L (Fed)	0.0005	0.0016	0.0005	0.0005	0.0005	0.0005	0.0005	0.0050	0.0006	0.0043	0.0008	0.00		0.01	0.00	0.00
CBOD mg/L (Fed)	2	2	2	2	2	2	2	2	2	5	2	3		5	2	2
Temperature C	10.4	10.8	11.8	12.0	15.3	18.5	20.7	20.8	21.1	18.4	15.3	13.2		21.1	10.4	15.7
Disinfection																
Total Chlorine Used Kg	62.7	81.3	93.6	133.6	130.2	128.8	121.9	104.1	134.2	124.3	117.7	109.6	1342.0	1342.0	62.7	206.5
Chlorine Dose mg/L	1.282	1.674	1.647	2.146	1.865	2.595	2.325	1.720	2.615	2.216	1.869	1.929		2.61	1.28	1.99
Chlorine Residual mg/l	0.64	0.85	0.78	0.86	0.53	0.82	0.99	0.78	0.90	1.25	0.82	0.82		1.25	0.53	0.84
E-Coli Average /100mL	10	17	13	10	10	10	10	22	10	10	12	13		22	10	12
Aeration																
Aeration Flow 1000m ³	51.301	55.013	59.009	66.515	76.492	50.845	52.846	61.505	51.795	56.449	66.039	58.068	705.877	76.492	50.845	58.823
# of tanks in service	2	2	2	2	2	2	2	2	2	2	2	2		2	2	2
Aeration Vol. 1000m ³	1.65	1.96	1.90	2.22	2.47	1.69	1.70	1.98	1.73	1.82	2.20	1.87		2.47	1.65	1.93
BOD (Influent) mg/L	78	87	295	117	131	131	159	130	167	159	283	148		295	78	157
S.S. (Influent) mg/L	115	173	733	139	220	248	214	250	675	185	232	368		733	115	296

	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18	TOTAL	MAX	MIN	AVG
Return Activated Sludge																
Total Flow 1000m3	199.05	176.17	139.92	125.69	140.70	149.45	139.27	157.32	154.18	153.88	126.59	187.61	1849.81	199.05	125.69	154.15
Plant Flow to Return %	431.21	370.64	250.84	200.44	199.47	299.47	266.21	261.30	300.71	274.68	119.49	330.12		431.21	119.49	275.38
Waste Activated Sludge																
Total Flow 1000m3	0.000	0.199	1.071	0.730	0.424	0.483	0.271	0.963	1.238	0.862	0.725	0.719	7.685	1.238	0.000	0.640
Septage Received																
Total Volume in m3	0	41	0	130	242	163	131	75	152	186	116	117	1351.93	241.50	0.00	112.66
Sludge Haulage																
Liquid Volume m3	0	0	0	0	0	0	1640	0	0	0	640	0	2280	1640	0	190
Sludge to Chatham m3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Hauled Sludge or Digester Contents (average)																
Total Solids	3.5	0.5	2.1	3.2	3.2	3.5	4.0	2.1	3.6	3.6	4.0	3.3		4.0	0.5	3.1
Volatile Solids	50	82	52	52	51	57	45	49	48	47	47	50		82	45	53
Ammonia ug/L	25	25	25	25	25	25	25	25	25	29	25	25		29	25	25
Nitrate ug/L	100	63	79	5	5	37	14	5	5	5	21	5		100	5	29
Nitrite ug/L	1.4	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5		1.4	0.5	0.6
TKN ug/L	1160	207	783	1250	1270	1070	1185	664	734	1200	1307	1220		1307	207	1004
Potassium mg/L	170	82	120	140	130	140	167	95	120	130	137	140		170	82	131
Total P mg/L	850	170	560	820	740	750	1087	520	690	830	827	380		1087	170	685
Arsenic As ug/L	0.3	0.1	0.2	0.3	0.3	0.3	0.4	0.2	0.3	0.4	0.4	0.2		0.4	0.1	0.3
Cadmium Cd ug/L	0.030	0.020	0.020	0.020	0.020	0.020	0.030	0.020	0.020	0.040	0.030	0.020		0.04	0.02	0.02
Chromium Cr ug/L	0.6	0.1	0.4	0.6	0.5	0.6	0.7	0.3	0.02	0.6	0.7	0.4		0.7	0.0	0.46
Cobalt Co ug/L	0.10	0.02	0.07	0.10	0.10	0.1	0.15	0.07	0.10	0.14	0.14	0.10		0.15	0.02	0.10
Copper Cu ug/L	5.5	1.0	4.0	5.9	5.5	5.0	7.8	3.2	4.6	6.1	6.0	2.8		7.8	1.0	4.8
Lead Pb ug/L	0.3	0.1	0.2	1.0	0.4	0.5	0.3	0.2	0.3	0.4	0.5	0.2		1.0	0.1	0.4
Mercury Hg ug/L	0.008	0.003	0.006	0.006	0.007	0.005	0.060	0.005	0.004	0.040	0.010	0.010		0.060	0.003	0.014
Molybdenum Mo ug/L	0.13	0.06	0.09	0.15	0.13	0.10	0.31	0.09	0.14	0.012	0.15	0.10		0.31	0.01	0.12
Nickel Ni ug/L	0.46	0.10	0.30	0.49	0.46	0.50	0.63	0.30	0.48	0.58	0.60	0.30		0.63	0.10	0.43
Selenium Se ug/L	0.20	0.20	0.20	2.00	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20		2.00	0.20	0.35
Zinc Zn ug/L	11	2	8	12	10	10	15	7	9	12	11	6		15	2	9
Ecoli cfu/g	200	70	310	690	100	180	17	840	340	150	377	560		840	17	320

Federal (Quarterly)

Final Flow Qtr. m3	192491.0	210750.0	197250.0	170754.00
CBOD Qtr. mg/L	2.0	2.0	2.0	3.27
SS Qtr. mg/L	6.0	8.1	6.8	11.37
Number of Days	90	91	92	92

Federal WSER Acute Lethality

Average Daily Volume Effluent (m ³):	2113
--	------

APPENDIX B

Calibration Reports for the Reporting Period

AS FOUND CERTIFICATION

PASS

CLIENT DETAIL		EQUIPMENT DETAIL	
CUSTOMER	Municipality of Chatham-Kent	[MUT] MANUFACTURER	Siemens
CONTACT	Todd Unsworth	MODEL	Sitrans LUT440
	Chief Operator - Wheatley WTP/STP	CONVERTER SERIAL NUMBER	PBD/F67220386
	115 Detroit Line, RR#1		
	Wheatley ON N0P 2P0	PLANT ID	Wheatley Pollution Control Plant
	t. 519-825-4183; c. 519-796-6089	METER ID	Final Effluent
	e. toddu@chatham-kent.ca	FIT ID	N/A
		CLIENT TAG	N/A
		OTHER	N/A
VER. BY - FM	Paris Machuk	GPS COORDINATES	N42 4.569 W82 27.449
Quality Management Standards Information - Reference equipment and instrumentation used to conduct this verification test is found in our AC-QMS document at the time this test was		VERIFICATION DATE	March 14, 2018
		CAL. FREQUENCY	Annual
		CAL. DUE DATE	March, 2019

PROGRAMMING PARAMETERS				TOTALIZER	
THROAT DIMENSION (DN)	inches	12		AS FOUND	2001341.39 M3
EMPTY DISTANCE	m	1.172		AS LEFT	2001392.72 M3
MAX. HEAD	m	0.281		DIFFERENCE	51.33 M3
DEAD ZONE	m	0.891		TEST CRITERIA	
BLANKING DISTANCE	m	0.300		AS FOUND CERTIFICATION TEST	Yes
MAX. FLOW	LPS	100.1		ALLOWABLE [%] ERROR	15
F.S. RANGE - O/P	LPS	100.0		COMPONENTS TESTED	
				CONVERTER DISPLAY	Yes
				mA OUTPUT	Yes
				TOTALIZER	Yes
				ACCURACY BASED ON [% o.r.]	No
				ERROR DOCUMENTED IN THIS REPORT; BASED ON % F.S.	

Ultrasonic sensor installed to ensure full scale flow condition

AS FOUND TEST RESULTS							
		0.0	7.2	20.8	38.5	94.1	% F.S. Range
REF. FLOW RATE		0.000	0.050	0.100	0.150	0.270	m
MUT [Reading]		0.000	7.232	20.769	38.497	94.178	LPS
MUT [Difference]		0.000	6.970	19.930	39.050	92.620	LPS
MUT [% Error]		0.000	-0.262	-0.839	0.553	-1.558	LPS
MUT [% Error]		n/a	-0.26	-0.84	0.55	-1.56	%
mA OUTPUT		4.000	5.156	7.320	10.155	19.057	mA
MUT [Reading]	min. 4.000 mA	3.996	5.036	7.181	10.136	18.870	mA
MUT [Difference]	max. 20.000 mA	-0.004	-0.120	-0.139	-0.019	-0.187	mA
MUT [% Error]		-0.02	-0.60	-0.70	-0.09	-0.93	%
TOTALIZER - REF. FLOW RATE						94.178	LPS
TOTALIZER [MUT]						5.71	M3
TEST TIME						62.01	SECONDS
CALC. TOTALIZER						5.840	M3
ERROR						-2.28	%

COMMENTS	QUALITY MANAGEMENT STANDARDS INFO.			RESULTS		
	[QMS] INFORMATION	IDENT.	ID #	TEST	AVG %FS	PASS FAIL
	[REFERENCE] LEVEL	Sim. BOARD	n/a			
	PROCESS METER	DMM	2	DISPLAY	-0.53	PASS
	STOP WATCH	SW	Yes	mA OUTPUT	-0.47	PASS
				TOTALIZER	-2.28	PASS

This report reflects the test results of the overall accuracy for the above flow converter using the specified manufacturers flow tube simulator to within the specified tolerance as identified within this report.

AS FOUND CERTIFICATION

PASS

CLIENT DETAIL		EQUIPMENT DETAIL	
CUSTOMER	Municipality of Chatham-Kent	[MUT] MANUFACTURER	Siemens
CONTACT	Todd Unsworth Chief Operator - Wheatley WTP/STP 115 Detroit Line, RR#1 Wheatley ON NOP 2P0 t. 519-825-4183; c. 519-796-6089 e. toddu@chatham-kent.ca	MODEL	Sitrans LUT400
		CONVERTER SERIAL NUMBER	PBD/EO210328
		PLANT ID	Wheatley Pollution Control Plant
		METER ID	Raw Influent
		FIT ID	N/A
		CLIENT TAG	N/A
		OTHER	N/A
		GPS COORDINATES	N42 4.569 W82 27.449
VER. BY - FM	Paris Machuk	VERIFICATION DATE	March 14, 2018
Quality Management Standards Information - Reference equipment and instrumentation used to conduct this verification test is found in our AC- QMS document at the time this test was		CAL. FREQUENCY	Annual
		CAL. DUE DATE	March, 2019

PROGRAMMING PARAMETERS				TOTALIZER		
THROAT DIMENSION (DN)	inches		9	AS FOUND	1628467.66	M3
EMPTY DISTANCE	m		1.093	AS LEFT	1628495.7	M3
MAX. HEAD	m		0.334	DIFFERENCE	28.04	M3
DEAD ZONE	m		0.759	TEST CRITERIA		
BLANKING DISTANCE	m		0.300	AS FOUND CERTIFICATION TEST		Yes
MAX. FLOW	LPS		100.0	ALLOWABLE [%] ERROR		5
F.S. RANGE - O/P	LPS		100.0	COMPONENTS TESTED		

Ultrasonic sensor installed to ensure full scale flow condition

CONVERTER DISPLAY	Yes
mA OUTPUT	Yes
TOTALIZER	Yes
ACCURACY BASED ON [% o.r.]	No
ERROR DOCUMENTED IN THIS REPORT; BASED ON % F.S.	

AS FOUND TEST RESULTS							
		0.0	5.5	15.8	45.6	84.9	% F.S. Range
		0.000	0.050	0.100	0.200	0.300	m
REF. FLOW RATE		0.00	5.47	15.80	45.63	84.85	LPS
MUT [Reading]		0.00	5.68	16.38	45.61	86.02	LPS
MUT [Difference]		0.00	0.21	0.58	-0.02	1.17	LPS
MUT [% Error]		n/a	0.21	0.58	-0.02	1.17	%
mA OUTPUT		4.000	4.875	6.528	11.301	17.576	mA
MUT [Reading]	min. 4.000 mA	3.998	4.899	6.624	11.430	17.801	mA
MUT [Difference]	max. 20.000 mA	-0.002	0.024	0.096	0.129	0.225	mA
MUT [% Error]		-0.01	0.12	0.48	0.65	1.12	%
TOTALIZER - REF. FLOW RATE						84.854	LPS
TOTALIZER [MUT]						7.09	M3
TEST TIME						81.43	SECONDS
CALC. TOTALIZER						6.910	M3
ERROR						2.54	%

COMMENTS	QUALITY MANAGEMENT STANDARDS INFO.			RESULTS		
	[QMS] INFORMATION	IDENT.	ID #	TEST	AVG %FS	PASS FAIL
	[REFERENCE] LEVEL	Sim. BOARD	Yes			
	PROCESS METER	DMM	2	DISPLAY	0.48	PASS
	STOP WATCH	SW	Yes	mA OUTPUT	0.47	PASS
				TOTALIZER	2.54	PASS

This report reflects the test results of the overall accuracy for the above flow converter using the specified manufacturers flow tube simulator to within the specified tolerance as identified within this report.

[MUT] AS FOUND

FAIL

[MUT] AS LEFT

PASS

CUSTOMER CONTACT
Municipality of Chatham-Kent
Todd Unsworth
Chief Operator, Wheatley
115 Detroit Line
Wheatley, ON N0P 2P0
T. 519-825-4183
C. 519-796-6089
E. toddu@chatham-kent.ca
VER. BY Randy Nichol

[MUT] MANUFACTURER
HACH
MODEL
HQ11d
SERIAL NUMBER
120800077797
CLIENT TAG
n/a
LOCATION
Wheatley STP
OTHER
n/a

TOLERANCE [pH] 0.05

Quality Management Standards Information -
Standards, reference equipment, and
instrumentation used to conduct this test outlining
the lot#, and expiry date is found in our current

VERIFICATION DATE March 26, 2018
CAL. FREQUENCY Annual
CAL. DUE DATE March-2019

pH VERIFICATION
NIST TRACEABLE (BUFFERS)

BEFORE CALIBRATION

REFERENCE BUFFER			[MUT] READINGS			
pH BUFFER	TEMP. °C	pH CORRECTED	pH	TEMP. °C	pH - ERROR DIFF.	PASS FAIL
4.01	19.4	4.00	4.06	19.3	0.06	FAIL
7.01	19.4	7.03	7.09	19.3	0.06	FAIL
10.01	19.4	10.06	10.13	19.3	0.07	FAIL
RESULT						FAIL

AFTER CALIBRATION

REFERENCE BUFFER			[MUT] READINGS			
pH BUFFER	TEMP. °C	pH CORRECTED	pH	TEMP. °C	pH - ERROR DIFF.	PASS FAIL
4.01	19.4	4.00	4.01	19.4	0.01	PASS
7.01	19.4	7.03	7.06	19.4	0.03	PASS
10.01	19.4	10.06	10.10	19.4	0.04	PASS
RESULT						PASS

mv offset/Assymetry 11
Slope -56.95

COMMENTS

[QMS] INFORMATION	ITEM	ID #
[REFERENCE]		
4.01 BUFFER	pHBUFF4	1
7.01 BUFFER	pHBUFF7	1
10.01 BUFFER	pHBUFF10	1
TEMPERATURE REF.	DDTEMP	1

NIST Traceable Buffers were used to confirm the overall accuracy of this instrument. "AS FOUND" readings and "AS FOUND" readings are reported within this report. A temperature device was used to measure and record the buffer temperature to correct for pH values due to the effects related to buffer temperature.

CUSTOMER CONTACT Municipality of Chatham-Kent
 Todd Unsworth
 Chief Operator, Wheatley
 115 Detroit Line
 Wheatley, ON N0P 2P0
 T. 519-825-4183
 C. 519-796-6089
E. toddu@chatham-kent.ca
VER. BY Randy Nichol

[MUT] MANUFACTURER Aysix
MODEL 3100
SERIAL NUMBER n/a
CLIENT TAG n/a
LOCATION Wheatley STP
OTHER n/a

Quality Management Standards Information -
 Standards, reference equipment, and
 instrumentation used to conduct this test outlining
 the lot#, and expiry date is found in our current

VERIFICATION DATE March 27, 2018
CAL. FREQUENCY Annual
CAL. DUE DATE March 2019

AS FOUND

Time	n/a
DO Concentration [%]	n/a
DO Concentration [mg/L]	9.4
Temperature	17.9
hpa	n/a

AS LEFT

Time	n/a
DO Concentration [%]	n/a
DO Concentration [mg/L]	10
Temperature	17.9
hpa	n/a

COMMENTS

Calibrated as per the manufacturers suggested practice
 used HQ30D as comparison.

[QMS] INFORMATION

ITEM

ID

NIST Traceable Buffers were used to confirm the overall accuracy of this instrument. "AS FOUND" readings and "AS FOUND" readings are reported within this report. A temperature device was used to measure and record the buffer temperature to correct for pH values due to the effects related to buffer temperature.

APPENDIX C

Effluent Parameter Concentration and Waste Loading Calculation Spreadsheet

CHATHAM-KENT PUC
WHEATLEY WW
EFFLUENT PARAMETER CONCENTRATION AND WASTE LOADING

2017	Jan-17	Feb-17	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17
BOD												
# of Samples Collected	5	4	4	4	5	4	5	4	4	5	4	4
Sum of Sample Results	4	8	8	8	10	8	10	8	12	10	10	8
Total S.S.												
# of Samples Collected	5	4	4	4	5	4	5	4	4	5	4	4
Sum of Sample Results	56	17	13	21	36	17	19	14	40	63	36	17
Total P.												
# of Samples Collected	5	4	4	4	5	4	5	4	4	5	4	4
Sum of Sample Results	1.63	1.17	1.04	1.01	2.41	1.84	2.36	2.88	3.15	2.90	1.18	2.28
Total Ammonia												
# of Samples Collected	5	4	4	4	5	4	5	4	4	5	4	4
Sum of Sample Results	0.740	0.201	0.200	0.344	1.120	1.470	0.688	1.305	3.790	5.620	0.350	0.440
Average Daily Effluent Flow 1000m3	2.294	2.103	2.023	2.489	2.581	2.297	2.157	2.085	1.828	1.540	2.223	1.609

2018	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18
BOD												
# of Samples Collected	5	4	4	5	4	4	5	4	4	5	4	4
Sum of Sample Results	10	9	8	10	10	8	10	8	8	28	8	21
Total S.S.												
# of Samples Collected	5	4	4	5	4	4	5	4	4	5	4	4
Sum of Sample Results	23	31	22	43	43	20	21	30	35	53	36	58
Total P.												
# of Samples Collected	5	4	4	5	4	4	5	4	4	5	4	4
Sum of Sample Results	1.17	0.92	0.86	1.74	2.68	2.15	0.87	1.32	0.85	1.53	0.79	2.73
Total Ammonia												
# of Samples Collected	5	4	4	5	4	4	5	4	4	5	4	4
Sum of Sample Results	0.342	0.218	0.748	0.524	0.360	0.200	0.310	0.644	0.750	11.050	1.110	1.420
Average Daily Effluent Flow 1000m3	1.910	2.529	2.015	2.340	2.724	1.870	1.978	2.264	2.192	1.701	1.894	1.975

Effluent Parameter Concentration over any consecutive 12 month period (CofA #1-822-83-006) reported in mg/L

	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18
BOD	1.96	2.13	2.13	2.13	2.17	2.17	2.17	2.17	2.10	2.44	2.40	2.65
Total S.S.	6.08	6.35	6.52	6.81	7.08	7.13	7.17	7.48	7.38	7.19	7.19	7.98
Total P.	0.45	0.45	0.35	0.45	0.46	0.47	0.44	0.41	0.36	0.34	0.33	0.34
Total Ammonia	0.31	0.31	0.32	0.31	0.30	0.28	0.27	0.26	0.20	0.31	0.32	0.34

Effluent Waste Loading over any consecutive 12 month period (CofA #1-822-83-006) reported in kg/d

	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Dec-18
BOD	4.1	4.5	4.5	4.5	4.6	4.5	4.5	4.5	4.4	5.2	5.0	5.6
Total S.S.	12.58	13.36	13.72	14.25	14.90	14.76	14.74	15.48	15.50	15.20	15.00	16.89
Total P.	0.93	0.94	0.73	0.94	0.97	0.97	0.90	0.84	0.76	0.71	0.69	0.72
Total Ammonia	0.63	0.64	0.67	0.66	0.64	0.58	0.56	0.54	0.42	0.65	0.67	0.72

Wheatley WPCP-Rated Capacity-2,752m3	
Effluent Parameter Limits	
BOD	25mg/L
Total S.S.	25mg/L
Total P.	1.0 mg/L
Effluent Waste Loadings Limits	
BOD	68.8kg/d
Total S.S.	68.8kg/d
Total P.	2.75kg/d

Jan-18	2.070	Average Daily Flow over any 12 month period reported in 1000m3
Feb-18	2.106	
Mar-18	2.105	
Apr-18	2.093	
May-18	2.105	
Jun-18	2.069	
Jul-18	2.054	
Aug-18	2.069	
Sep-18	2.100	
Oct-18	2.113	
Nov-18	2.086	
Dec-18	2.116	

Effluent Concentration - 2018	MIN	MAX	AVG
BOD	1.96	2.65	2.22
Total S.S.	6.1	8.0	7.0
Total P.	0.33	0.47	0.40
Total Ammonia	0.20	0.34	0.29

Effluent Waste Loading - 2018	MIN	MAX	AVG
BOD	4.06	5.62	4.64
Total S.S.	12.6	16.9	14.70
Total P.	0.69	0.97	0.84
Ammonia	0.42	0.72	0.61